



# CORRIGENDUM FOR TENDER FOR ELECTRICAL & LAN CABLING WORK AND FURNISHING OF BARODA U.P BANK REGIONAL OFFICE BALLIA II

Please refer to tender 2022-23/ROB-II/GB/378 DATED 03.06.2022 regarding ELECTRICAL & LAN CABLING WORK AND FURNISHING of regional office Ballia-II. Due to unavoidable reason the tender stands cancelled and new tender is enclosed herewith.

Inconvenience is deeply regretted.

Date: 06.06.2022

Regional Manager

Ballia II



पत्रांक: 2022-23/RUB II/QB/ 416

दिनांक : 06.06.2022

### TENDER FOR ELECTRICAL & LAN CABLING WORK AND FURNISHING OF BARODA U.P BANK REGIONAL OFFICE BALLIA II

Baroda UP Bank, Regional Office, Ballia-II, Indira Market Near Chittu Pandey Chauraha, Ballia invites sealed tender for ELECTRICAL & LAN CABLING WORK AND FURNISHING for Regional Office Ballia II.

01. Tender Issuing Date

: 06.06.2022

02. Last Date of submission of Tender

: 13.06.2022 till 11.00 AM

03. Date of Opening of Tender

: 13.06.2022 till 3.00PM (Depends on availability

Of Tender Committee)

04. Tender to be Addressed to

: The Regional Manager Baroda UP Bank Regional Office, Ballia-2

Indira Market, Near Chittu Pandey

Chauraha, Ballia, 277001

### Terms & Condition of Tender:

Rates should be quoted on the space provided in the <u>annexure attached only.</u> No other sheet/form should be used for quoting rates.

Rates quoted only by bank's empanelled Vendor will be consider/accepted.

The competent Authority (Bank) does not buying themselves to accept the lowest or to give any reasons for its decision of acceptance or rejection of tenders.

Incomplete in any respect or conditional tender shall liable to be rejected.

### Other Conditions

The registration number along with GST no. allowed by the authorities must be submitted.

> PAN NUMBER of the firm allotted by the income tax authorities should be submitted (without which vendor's bid would became invalid and shall be liable to be reject).

Conditional tenders shall not be accepted on any ground and shall be rejected straight.

Any deviation of the conditions given by the purchaser will not be accepted and bid will be rejected without assigning any reasons.

If any clarification is required the same should be obtained before submitting the bid.

The Entire document must be signed with the seal and attached as a mark of acceptance of the terms &

BUPB's reserve the right to accept or reject any bid whole or in parts without assigning any reason thereof.

Bank's decision will be final and no correspondence will be entertained in this regard.

In case of delay in submission/non submission of bids, Bank will not assume any responsibility.

Bank may reject any or all quotation without assigning any reason.

Submission of the tender in sealed envelope super scibing "TENDER FOR ELECTRICAL & LAN CABLING WORK AND FURNISHING OF REGIONAL OFFICE BALLIA II" addressed to Baroda UP Bank, Regional office Ballia-II ,Indira market, near chittu pandey chauraha, Ballia- 277001, complete in all respect by 11.00 AM dated 13.06.2022. Tenders received after shall not be entertained. Tender must be submitted through hand to hand or through register post.

### Evaluation of Tender:

Quoting incredibly low value of items with the view of subverting the tender process shall be rejected staright away.

Yours' Faithfully

(A.K Dubey) Regional Manag

> क्षेत्रीय कार्यालय, बलिया-प्रथम, इन्दिरा मार्केट, निकट चित्तू पाण्डेय चौराहा, बलिया-277001, टेलीफोनः 05498-222417, 6389203010 Regional Office, Ballia-I, Indira Market, Near Chittu Pandey Chauraha, Ballia-277001, Telephone: 05498-222417. 6389203010 e-mail: ROBALL@barodauprrb.co.in

## Detail Estimate for Tender work LAN Cabling work of Regional Office Ballia-2

Sl.No.	Particulars	Qty.	Unit	Rate/Unit	A	ount
1.	S/F of plug socket board consisting of 3			Rs. P.	Rs.	
	plug 5 Amp, three pin 41	23	No	1.	Ks.	P.
	plug 5 Amp, three pin, three switch and one					
	indicator with 1.5 sq mm separate circuit wiring for computer.					
2.	S/F of LIPS earthing S/L					
	S/F of UPS earthing-S/burying of Dual pipe	3	No			
	technology (Pipe in Pipe) earthing of Dual pipe					
	having Gl 80mm O/D pipe with 25 micron					
	coating, 3metres long. The space between two					
	pipes to be filled with Highly conducive & Non		1			
	corrosive chemical compound. The vacant space					
	between pipe & hole shall also be filled with					
	Compound all around. The job also includes S/F					
	of GI strip clamp with two holes (with SS/GI					
	bolts & nuts) on the electrode& taking two					
	earthing leads of 4mm dia copper wire					
	(Assumed length of 10m -beyond 10m to be					
	paid extra) upto Main panel complete in all					
	respects with guaranteed E/N voltage of less					
	than 2 volts and resistance less tahn 10hms. The					
	4mm dia Cu. earth wire shall be terminated on a					
	separate 6way earthlink. The connections for					
	Panel earthing& earth					
	bus in the panle should be taken from this					
2	earthlink					
3.	Supplying and fixing recessed mounting fittings	22	No			
	with suitable for 35/40 watt LED 600x600					
	Square fitting with PDC Aluminum die cast					
	housing with poly Corbonet diffuser, in built					
	electrical 110 LM Per watt protection like over					
	voltage, short circuit, over loading, mis wiring					
	for additional safety precaution rated light					
	50000 hours, (Guaranteed for above LED light					
	is three month from period of installation)				1	
	Make Crompton Cat No. LCTLRNE-36-FO-					
	CDL,LED 36W or Philips make Model No. 380					
	LED 42S DN (38 W) Wipro Cat- Garnet Slim					
	LED D414065 (All complete with Lamps					


Sl.No.	Particulars	Qty.	Unit	Rate/Unit	
4.	S/W 10 Amm DI	4.3.	Cint		Amount
	S/W 10 Amp, Plug point with 2.5 sq mm copper wire in counter with continuous earthing wire complete in all respect with modular switches /socket.	21	No	Rs. P.	Rs. P.
5.	S/F of LED Batten 20 watt light Fitting with 1.5 sq mm wiring complete in all respect including modular switches	6	No		
6.	S/F of 20 Amp plug point with 2.5 sq mm wiring including modular switches /socket with continuous circuit wiring.	18	No		
7.	Supplying and wiring for Telephone point with twisted annealed, copper conductor PVC insulated and PVC sheathed telephone wire with socket in 14 SWG with all the accessories in concealed manner with 2-pin socket in suitable size of MS box.	20	No		
8.	Supplying and fixing 4 WAY TPN DB Double door 1p43 With10-32 amp SP MCB 10 KA & 63 AMP 4 POLE MCB For A.C	3	No		
9.	Providing & Fixing of wall fans& point complete with 1.5 Sq mm wiring and modular switches.	20	No	a.	
10.	Supplying and fixing of Call Bell in BM's cabin including wiring etc.	2	No		
11.	Supplying and Fixing of cabin fans (400Dia) in cash cabin/ in 1.5 sq mm wiring and modular switches.	0	No		
12.	Supplying and Fixing of circuit wiring for computer in 2.5 sq mm copper wire.	16	No		
13.	Supplying and Fixing of wiring for lights and fans 1.5 sq mm copper wire complete in all respect.	16	No		

Sl.No.	Particulars	Qty.	Unit	Rate/Unit	Amoun
14.	Supplying and Fixing recessed mounting fittings with suitable for 18/20 Watt LED down Light fitting with PDC Aluminiumdiecast housing with Poly Corbonet diffuser, in built electrical protection like over voltage, short circuit, over loading, mis wiring for additional safety precaution rated light 50000 hours, (Guaranteed for above LED light is three month from period of installation) Philips make DN195BLED 20F (20 WATT) 6500 KA < Crompton Cat No. LCBE18 – CDL-18 Watt & Wipro cat- Gernet slim D7112060/40/30 6500 KA (complete with all)	30	No	Rs. P.	Rs.
15.	S/F of A.C. point wiring with 2x 4 sq mm+1x1.5 sq mm copper wire and metal socket MCB 20 Amp. complete For 1.5 Ton/	14	No		
16.	Supplying and Fixing of exhaust fan in toilet/hall 15 1nch dia 1.5 sq mm wiring and modular switches.	2	No		
17.	S/F of ceiling fan (1200 dia) with hooks in rooms with adding rod of suitable length wherever necessary including 1.5 sq mm wiring and modular switches and regulator.	1	No		
18.	5 & F of 12 way SPN DB double door with 10No SP MCB and 1 no DPMCB 40 AMP for computer	3	No		
19.	Supplying and fixing 4 WAY TPN DB Double door 1P43 With 10-32 amp SP MCB 10 KA & 63 AMP 4 POLE 100 MA RCCB For light, Fan & Supply complete	1	No		
	Sub main wiring of UPS input and UPS output power supply with 2 no 6 sq mm No. 4 sq mm copper flexible wire in PVC conduit pipe. (payment as/actual length on site)	65	Mtr		

Sl.No.	Items of Work	Qty.	Unit	-		
21.	Sub main wising C	Qiy.	Unit	Rate/Unit	Amo	ount
	Sub main wiring of power supply from	65	-	Rs. P.	Rs.	P
	Main to TPN distribution Board with 4 nos	03	Mtr			
	10 sq mm copper flexible wire and 1 no 6 sq mm earth wire in PVC condition					
	mm earth wire in PVC conduit pipe.					
					1	
22.						
	Supplying / Fabricating / installation of Panel Board made of 16 gauge CRC sheet	1	Set			
	415 V sheet		500			
	Incoming, Thursday					
	Incoming: TPN MCCB 250 Amp_1 No 36 KA (4 pole)					
	CA (4 pole)					
	Out going 100 Amp MCCB 4 pole -3 no				1	
	110 and 03 Amp 4 Pole MCD					
	With Double Bus Bar Chamber		1 1			
	ous Dai Chamber					
	Complete with materia					
23.	Complete with metering system				1	
-5.	Supply and fixing of Main line cable work	30	1			
		30	Mtr			
	edole Willi Willing (I engly to be and )					
-						
24.	Supply and fixing on board 3 no KIT				1	
	KAT cut out 200 amp with neutral link on	1	Job			
	board board				1	
25.	S/F of ceiling fans (1200 dia) with hooks in					
	rooms with adding (1200 dia) with hooks in	0	No			
	rooms with adding rod of suitable length		1.0			
	microver necessary including 1.5 and					
26.	I writing and modular switches and regulate					
20.	3/F of light point (LED light 9 wast) := 1.5	0				
	of till Wifing complete in all respect	0	No			
	include modular switches.					
	LAN Cabling					
27.	Supplying and drawing CAT 6 PVC					
	insulated and Shoothad Lass	700	Mtr			
	insulated and Sheathed LAN cable through					
	PVC conduit including testing,	1				
20	commissioning etc. as required.					
28.	Supply and fixing of RJ modem lack for	24				
	computer including making connection	24	No			
	soldering etc					
		1				
		- 1			1	

29.	Supply and Fixing of Patch Card with CAT				
	6 Jack	24	No		
				1	
				Total Rs.	

	GST18%	
(0.	GRAND TOTAL	
(Rs Lacs Thousand Hun	dred O	nly.)



### PROPOSED PLAN FOR:-

BARODA U.P. BANK, REGIONAL OFFICE, BALLIA-2

DRW. TITLE :- GROUND FLOOR INTERIOR PLAN S-

PLAN - II

Ar. RAJESH KUMAR SINGH

(B.Arch) <u>VISION ARCH</u>

Plot no. 166, V.D.A. Colony, Badalalpur (Chandmari) Varanasi M.No. 9450165944 E MAIL: VARCH0036@GMAIL COM

### PROJECT - SPECIFICATION FOR FURNITURE & ELECTRICAL WORKS.

### BANK BARODALP BANK

### REGIONAL OFFICE BALLIA 2

### \*ALL WORKS TO BE DONE AS PER TENDER CONDITIONS.

A	FURNITURE ITEMS	
1	LAMINATES (IS-2046) / VENEER	GREEN LAM / CENTURY / ARCHID / SAMRAT /
	CAMINATES (IS 2046) / VENEER	FORMICA / SUNDEK OR APPROVED EQUIVALENT
		ARCHID/ SAMRAT / CENTURY / EURO / GREEN OR
2	COMMERCIAL PLY (IS-303) /	
	WATERPROOF PLY (IS-710) / BLOCK	APPROVED EQUIVALENT BY EIC.
	BOARD (IS-1659) / FLUSH DOOR (IS- 2202)	
3	ADHESIVES	FEVICOL / BLUECOAT/ VAMICOAL
4	LOCKS	GODREJ
4	MULTIPURPOSE GROUP LOCK	E-MPL1-22 / E-MPL1C-22 (EBCO)
	NIGHT LATCH	8812 (GODREJ)
	CYLINDRICAL LOCK (SS MATT FINISH)	3792-WITH KEY AND 3786-KEYLESS (GODREJ) /
	CTB/CD/CCCCCA (35 CAPACIA)	C120SS
		(EUROPA)
	MORTISE DEAD LOCK (TWO WAY)	8815(GODREJ)
	MORTISE LOCK WITH DOOR HANDLE	MATIZ 8083(GODREJ)
5	DRAWER CHANNELS	GODREJ/ HATTICH/ OZONE
	TELESCOPIC CHANNELS (ZINK PLATED)	STDS35(I)35/ STDS25(I)35/ STDS50(I)35/
	Telesco de comune de	STD\$60(I)35
_	BOTTOM CHANNELS (POWDER COATED)	BMDS 35/ BMDS 37/ BMDS 55/ BMDS 60 (EBCO)
	50(10.11.67)	
6	GENERAL HARDWARE	SS MATT FINISH
0	DOOR STOPPER	I) BLACK/IVORY/BROWN/SILVER COLOR POWDER
	2001.200	COATED DS1 (EBCO)
		II) SPRING TYPE BLACK/BROWN/IVORY COLOR
		POWDER COATED (ECGL'S STERLING)
		I) 3"/4"/5"/6" 1.8MM TH. SS MATT FINISH (SUZU)
		II) 75X12X19 1.2 MM TH. SS MATT FINISH FOR
		STORAGE (SUZU)
	HINGES	III) AUTO CLOSE HINGES - SLIP ON HINGE- EURO
		CLICK ON HINGE-I (EBCO) FOR STORAGE
	HANDLES 'D' OR 'C' TYPE	1) 3"/4"/6"10MM DIA SS 202 MATT FINISH (ANI/
	nanbees 5 on 5	
	TOWER BOLT	3"/4"/6"/8" BRASS EXTRUDED SS MATT FINISH
	TOWER BOLT	(OSWAL)
		(OSTIAL)

	SLIDING CHANNEL	EBCO MAKE APPROVED BY ARCHITEC/BANK.
7	FLOOR SPRING	
	60 KG	7477 (GODREJ) / M-74 (HARDWYN)
	80 KG	8293 (GODREJ) / M-74 (HARDWYN)
	100 KG	8294 (GODREJ) / M-76 (HARDWYN)
8	DOOR CLOSER	
	60 KG	DOUBLE SPEED 8292-SILVER, 7325- GOLDEN
		(GODREJ) /
		SCORPIO (HARDWYN)
	FIRE RATED 60 KG	1938 (GODREJ) / TRITON (HARDWYN)
9	PATCH FITTINGS FOR DOOR AND FIXED	GODREJ / XL C SERIES(DORMA) / OPF SERIES
	GLASS PARTITION (TOP/BOTTOM PATCH,	(OZONE) OR APPROVED EQUIVALENT
	PIVOT, PATCH LOCK, L ARM, L CONNECT,	
	CONNECTOR, FLOOR	
	SPRING, HANDLE, PLASTIC PROFILE)	
10	GLASS / MIRRORS	SAINT GOBAIN / MODI
11	ALUMINUM SECTION	JINDAL / INDAL / BANCO
12	WINDOW BLINDS	VISTA / AEROLUX/HUNTER DUGLUS / MAC
13	POLISH / PAINT	ASIAN PAINTS / BERGER / NEROLAC
14	PARTICLE BOARDS	NOVAPAN / DECO BOARD
15	COMPUTER ACCESSORIES	SUPERAL CONTROL OF CON
	CPU HANGER/ SHELF	SIDE MOUNTED IS CPU HL SM (INNOFITT)
		/CPUSM(EBCO),
	CABLE MANAGER (60MM)	I) METAL - CO60ZN1(EBCO)
		II) PVC - CO 60 (EBCO) BLACK/IVORY/GREY COLOR
16	ACP PANEL	TIMEX / ALU DECOR / EURO OR APPROVED
		EQUIVALENT
19	WHITE FILM FOR GLASS	CRYSTAL / SONA MAKE VINYL FROSTED FILM
В	DAINTS	ICI, ASIAN, DULUX, BERGER, NEROLAC, JOHONSON
	PAINTS	& NICOLSAN
1	ANTI CORROSIVE PAINT	TIKITAR, FINCOAT
2	RED OXIDE	ASIAN, DULUX,NEROLAC
3	POLISH	ASIAN MELAMINE
4	EXTERIOR PAINTS	DULUX WEATHERSHIELD OR APP. EQUIVALENT
5	ENAMEL PAINT	ICI, DULUX, ASIAN, NEROLAC
С	FALSE CEILING	
1	GYPSUM BOARD	GYPROC (SAINT GOBAIN)
2	FRAMING WITH COMPLETE SYSTEM	GYP STEEL ULTRA (SAINT GOBAIN), RAMCO FUJI
3	HILUX BOARDS	RAMCO OR APPROVED EQUIVALENT
4	MINERAL FIBRE TILES CEILING WITH	ARMSTRONG/SAINT GOBAIN/USG
	COMPLETE SYSTEM	

D	APPROVE MAKE LIST FOR ELECTRICAL	
	PVC rigid conduits & Accessories:	
	a Accessories:	1.5 mm thick ( MMS ) ISI and FIA approved - Precision
		/ Vraj / Nihir / BLP / PFI / Anchor / Polycab make. (
		Only white coloured pipes FRLS
	L.T. Cables:	type to be used. ).
		Havells / KEI / Polycab / R. R. Kable / Finolex.
	Wires (FRLS):	Havells / KEI / Polycab / R. R. Kable / Finolex.
	Main Distribution Boards:	MDS Legrand (Lexic ) / Hager / Crabtree XPOA /
		Schneider (Eazy 9)/
		L & T EXORA / C & S Wintrip / Siemens Bitaguard.
5	ELCB / RCCB / Miniature Circuit Breaker:	MDS Legrand (Lexic ) / Hager / Crabtree XPOA /
		Schneider (Eazy 9)/
		L & T EXORA / C & S Wintrip / Siemens Bitaguard.
6	Switch gears:	MDS Legrand (Lexic ) / Hager / Crabtree XPOA /
		Schneider (Eazy 9)/
		L & T EXORA / C & S Wintrip / Siemens Bitaguard.
7	Change Over Switch:	HPL Socomac/ Havells / L & T / Hager.
8	Domestic fittings:	
	a) All Switching Modular Accessories.	MK Wrapped Wround Plus / Schneider Livia / L & T
		entis / Crabtree
1		Verona / Salzer Elite / Legrand Myris / C & S Divino /
	12.00	SSK Ace.
·	b) Holders / ceiling roses	Anchor or equivalent approved make.
9	c) Adhesive Tape	Bhor (Steel Grip) or approved .
9	10 - 30 A Polycarbonate Socket & Top:	MDS Legrand (Lexic ) / Hager / Crabtree XPOA /
		Schneider (Eazy 9)/
10	Talanka a Milanda (C. L.)	L & T EXORA / C & S Wintrip / Siemens Bitaguard.
11	Telephone Wires / Cable:	Finolex / R. R. Kable / Havells / L & T / Polycab.
12	Telephone tag block: Cable Lugs:	Krone make.
13		Dowell / Lotus / Jainson / 3 D.
13	Cable gland Single / Double Compression:	HMI / Comet / 3D.
14	Ammeter / Voltmeter:	AE / HPL /MECO/ Enercon make.
15	Selector switches:	L&T salzer / Kaycee make.
16	Indicator lamps:	LED type Teknic / Precifine/ Binay.
17	Connector strips:	Wago / Elmex make.
18	Lighting Fixtures :	Wipro / Philips / GE / Crompton. only
19	Exhaust fan (Light duty):	Khaitan / Crompton / Havells.
20	Ceiling Fan ( 5 star rated ):	Crompton / High Propers Plant Action
21	Wall mounted Fan ( 5 star rated ):	Crompton ( High Breeze Plus ) / Havells.
22	Data Cable - I / O Unit:	Crompton ( High Flow Wave) / Havells.
~ 6-	Para Cable - 1/ O Offit.	D - Link / Digi Link.