

RO/ALLA/P&E/2022-23/19

Date:- 06.07.2022

TENDER FOR ELECTRICAL WORK, LAN CABLING, FALSE CEILING & SIDE UNITS OF REGIONAL OFFICE ALLAHABAD

Baroda UP Bank Regional Office Allahabad, 3 D Tashkant Marg Civil Line, invites sealed tender for furnishing for our **Regional Office** (Dist- Prayagraj) from the empanelled Furnishers of Baroda UP Bank, Head Office, Buddh Vihar Taramandal Gorakhpur-273016 (U.P).


- | | |
|---------------------------------------|---|
| 1. Tender issuing date | : 06.07.2022 |
| 2. Last date for submission of tender | : 21.07.2022 at 3:00 PM |
| 3. Date of opening of tender | : 22.07.2022 at 3.00 PM |
| 4. Contact Number | : 7839884103 |
| 5. Tender to be address to | The Regional Manager
Baroda UP Bank,
Regional Office- Allahabad, 3D Tashkant Marg Civil Line;
211001 |

Terms and condition of tender:

- Ø Rates should be quoted on the space provided in **annexure attached only**. No other sheet/form should be used for quoting rates.
- Ø The competent authority (bank) does not bind themselves to accept the lowest or to give any reasons for its decision of acceptance or rejection of tenders.
- Ø Incomplete in any respect or conditional tender shall liable to be rejected.
- Ø Rates quoted only by bank's empanelled vendors will be consider/accepted.

Other conditions:

- Ø The registration number of the firm along with **GST no.** allotted by the authorities must be submitted.
- Ø **PAN NUMBER** of the firm allotted by the income tax authorities should be submitted (without which the vendor's bid would become invalid and shall be liable to reject)
- Ø Conditional tenders shall not be accepted on any ground and shall be rejected straight.
- Ø Any deviation of the conditions given by the purchaser will not be accepted and bid will be rejected without assigning any reasons.
- Ø If any clarification is required the same should be obtained before submitting the bid.



- Ø The entire document must be signed with the seal and attached as mark of acceptance of terms and condition.
- Ø BUPB reserve the right to accept or reject any bid whole or in parts without assigning any reason thereof.
- Ø Bank's decision will be final and no correspondence will be entertained in this regard.
- Ø In case of delays in submission/non submission of bids ,Bank will not assume any responsibility.
- Ø Bank may reject any or all quotations without assigning any reason.

Tender submission:

Submission of tenders in sealed envelope super scribing "TENDER OF FURNISHING OF REGIONAL OFFICE ALLAHABAD" addressed to "The Regional Manager Baroda UP Bank, Regional Office-Allahabad, 3D Tashkant Marg Civil Line; 211001", Complete in all respect latest by 3.00 PM dated-21.07.2022 Tenders received after that shall not be entertained.

Tender must be submitted through hand to hand or through registered post.


Evaluation of tender:

Quoting incredibly low value of items with a view of subverting the tender process shall be rejected straight away.

Yours faithfully,



(Soran Singh)
Regional Manager



**Detail Tender for Electrical work LAN Cabling Work & False Ceiling + Side Units of
Regional Office Prayagraj**

Sl. No.	Particulars	Qty.	Unit	Rate/Unit		Amount	
				Rs.	P.	Rs.	P.
1.	S/F of plug socket board consisting of 3 plug 5 Amp, three pin, three switch and one indicator with 1.5 sq mm separate circuit wiring for computer .	28	No				
2.	S/F of UPS earthing-S/burying of Dual pipe technology (Pipe in Pipe) earthing electrode having GI 80mm O/D pipe with 25 micron coating, 3metres long. The space between two pipes to be filled with Highly conducive & Non corrosive chemical compound. The vacant space between pipe & hole shall also be filled with Compound all around. The job also includes S/F of GI strip clamp with two holes (with SS/GI bolts & nuts) on the electrode& taking two earthing leads of 4mm dia copper wire (Assumed length of 10m -beyond 10m to be paid extra) upto Main panel complete in all respects with guaranteed E/N voltage of less than 2 volts and resistance less tahn 1ohms. The 4mm dia Cu. earth wire shall be terminated on a separate 6way earthlink. The connections for Panel earthing& earth bus in the panle should be taken from this earthlink	3	No				
3.	Supplying and fixing recessed mounting fittings with suitable for 35/40 watt LED 600x600 Square fitting with PDC Aluminum die cast housing with poly Corbonet diffuser, in built electrical 110 LM Per watt protection like over voltage, short circuit, over loading, mis wiring for additional safety precaution rated light 50000 hours, (Guaranteed for above LED light is three month from period of installation) Make Crompton Cat No. LCTLRNE-36-FO-CDL,LED 36W or Philips make Model No. 380 LED 42S DN (38 W) Wipro Cat- Garnet Slim LED D414065 (All complete with Lamps	36	No				

4.	S/W 10 Amp, Plug point with 2.5 sq mm copper wire in counter with continuous earthing wire complete in all respect with modular switches /socket.	24	No		
5.	S/F of LED Batten 20 watt light Fitting with 1.5 sq mm wiring complete in all respect including modular switches	10	No		
6.	S/F of 20 Amp plug point with 2.5 sq mm wiring including modular switches /socket with continuous circuit wiring.	20	No		
7.	Supplying and fixing 4 WAY TPN DB Double door 1p43 With 10-32 amp SP MCB 10 KA & 63 AMP 4 POLE MCB For A.C	04	No		
8.	Providing & Fixing of wall fans & point complete with 1.5 Sq mm wiring and modular switches.	30	No		
09.	Supplying and fixing of Call Bell in BM's cabin including wiring etc.	02	No		
10.	Supplying and Fixing of cabin fans (400Dia) in cash cabin/ in 1.5 sq mm wiring and modular switches.	0	No		
11.	Supplying and Fixing of circuit wiring for computer in 2.5 sq mm copper wire.	20	No		
12.	Supplying and Fixing of wiring for lights and fans 1.5 sq mm copper wire complete in all respect.	20	No		

